

**Inspection Report of RNC Station by Sri. Avanish, Sr. DCM/RNC**  
**on 22.10.2019.**

Accompanied by .DEN(E)/RNC & ACMS /RNC

<b>STATION : Ranchi (RNC)</b>		
<b>CATG : NSG-3</b>		
Staff on duty: Dhruw Kumar,SMR/RNC		
1.	<b>Passenger Amenities:</b> <ol style="list-style-type: none"> <li>Sequence of ceiling fan of PF shelter needs to be looked into ,08 Nos additional fans required at PF 2&amp;3.</li> <li>Towel rod to be fixed in Pay &amp; use toilet near parcel office.</li> <li>PF number board for PF-1A is required.</li> <li>Foot step for urinal in 2<sup>nd</sup> class gents waiting hall is required.</li> <li>Door closer to be fixed in upper class waiting hall &amp; CCTV Room.</li> <li>Curtain to be fixed in ladies toilet inside ladies waiting hall.</li> <li>One exhaust fan not working in 2<sup>nd</sup> class Gents waiting hall .</li> </ol>	Sr.DEN(CO) Sr.DEE(G)
2.	<b>Safety:</b> <ol style="list-style-type: none"> <li>Housing of point to be rectified in point nos.117,121B,125A</li> <li>Proper barricading to be done in lift area near facilitation centre.</li> <li>Exhaust fan not available at mechanized laundry (Blanket cleaning) Room, needs to be provided.</li> <li>Only four fire extinguishers found at mechanized laundry, additional 04 nos fire extinguisher needs to be provided.</li> </ol>	Sr.DEN(CO) Sr.DME Sr.DEE(G)
3.	<b>Misc:</b> <ol style="list-style-type: none"> <li>Gents and ladies to be written separately in EI building toilets.</li> <li>Drying tumbler at mechanized laundry was not working.</li> <li>Wash basin at mechanized laundry found broken condition.</li> <li>Cleaning condition of toilet in mechanized laundry was not good. As per SMR/RNC ,area of mechanized laundry not included in cleaning contract, needs to be looked into.</li> <li>Seepage found from pipe at the top near entrance of booking office gate at PF-1 .</li> </ol>	Sr.DEN(CO) Sr.DME

No.Sr.DCM/RNC/Insp/19

(Avanish)  
Sr.DCM/RNC

- Copy to: i) PS to DRM/RNC for kind information of DRM/RNC please.  
 ii) ADRM(O)/RNC for kind information please.  
 iii) Sr.DEN(CO)/RNC ,Sr.DEE(G)/RNC,Sr.DME/RNC, DEN(E)/RNC &,ACMS/RNC for information and necessary action.

  
 (Avanish)  
Sr.DCM/RNC